PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

NO	Date: <u>옥5/11/옥</u> 0곡곡
It is certified that an inspection team headed by Mus Ty Shivai Public School (School Name (School Address) on 25.11.22 (Date) and found that the Shiv (Shivaji Public School) at Rand Barth Rand.	examp (School Address) has safe
drinking water facilities for the students and members of staff	1
sanitation condition in the school building & the campus as per th	ne norms prescribed by the Central/State/U.T Govt.
The above for a period of	ignature with Seal :
	Name:

To

Yhe Principal

Shivasi Public School

Khazi Backh Rosa, Chool

(Jaipur)

Name of School and Address

OFFICE OF THE SENIOR CHEMIST

Public health Engineering Department Laboratory

GOVINDGARH, Jaipur (Rajasthan)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

NO. Lab/Tech. (chem.)2023-2024/ 18 9 CHOMU JAIPUR, RAJASTHAN

Date:- 25/11/2022

District:- Jaipur

Block :- Govindgarh

Block :- Govingar				
Source	TW	BIS10500:2012 Drinking		
			Water Standards	
Location of Source	Chomu	Max.	Max.	
Village/ Town	Chomu Jaipur	Desirable	Permissible	
Date of Collection		Limit	Limit	
Lab Sample No.	U245			
Note: All Results except PH are in mg/lit				
1. PH	6.89	6.5-8.5	NR	
2. Turbid (NTU)	0.88	1	5	
3. Temperature(°C)				
4. Colour				
5. Odour				
6. Total Alkalinity	230	200	600	
7. Total hardness(as CaCO ₃)	180	200	600	
8. Calcium Hardness (as CaCO ₃)				
9. Magnesium Hardness (as CaCO ₃)				
10. Chloride (as Cl)	44	250	1000	
11. Sulphate (as SO ₄)	27			
12. Nitrite (as No ₂)				
13. Nitrate (as NO ₃)	35	45	NR	
14. Fluorides (asF')	0.140	1	1.5	
15. Total Dissolved Solids	382	500	2000	
16. Residual Chlorine				

Remarks:- Sample Not Collected By Lab

Director

Shivaji Gramin Vikas Shiksan Sanstham

Chomu, Jaipur

PRINCIPAL
SHIVAJI PUBLIC SCHOOL
Khadi Ragh Road, CHOMU, Jaipur

Signature with Seal : ...

Designation:

A

शिवाजी ग्रामीण विकास शिक्षा संस्थान, खादी बाग रोड़, चौमूँ